

Connection and supply conditions for sprinkler systems

Sprinkler systems must be installed according to the recognized technical standards and with the approval of the Munich Municipal Fire Department.

The prices listed apply to installation heights of up to 3 m. Any additional costs incurred for installation heights of over 3 m and for special stand constructions (surface installations and for the bypassing of summers and stand components, etc.) are charged for.

The complete documents (as described in form 1.3), orders and plans must be submitted to MunichExpo Veranstaltungen GmbH by the specified deadline at the latest (see "Important Notes"), however, for two-storied and covered stands no later than six weeks before the start of construction.

No guarantee can be given that installations ordered after this date will be completed on time.

MEV reserves the right to charge an additional fee for late orders.

The sprinkler pipes are installed in the halls according to the dimensions specified in the plan. The position of the shut-off valve on the ground floor must be specified by the exhibitor / stand builder. The supply pipe will be laid if possible in the utility conduits but may be laid above ground if the position of the shut-off valve and the successive sprinkler installation downstream of it require this (on request, we will indicate the placement of the basic sprinkler pipe / outlet). The sprinkler installation itself is always installed in front of the walls and under the suspended ceilings. The sealed shut-off valve must remain accessible at all times and must not be built over or obstructed. The exhibitor shall be liable for damage resulting from noncompliance with this regulation.

The General Terms of Contract for Exhibitor Services of MEV apply additionally.

Design data:

Exhibition halls in accordance with VDS are in fire risk class BG 2.3.

– Maximum protection area per sprinkler nozzle 12 m² by means of glass bulb sprinkler DN 15, nominal opening temperature 68°C, color red.

– Separate cabins and rooms must also be provided with sprinklers in conformance with the maximum protection area of 12 m² / nozzle.

– A maximum of 18 sprinkler nozzles may be connected for each DN 50 connecting pipe in the utilities conduit. The pipe dimension of feeder pipes to the nozzles is also DN 50.

– Structures suspended from the hall ceiling (trusses, etc.) cannot be fitted with a sprinkler system.